

DATA HASIL PENYELIDIKAN TANAH KAB. KAUR SELUMA PROV. BENGKULU

No.	Kec. Tanjung Iman	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa. Tanjung Iman	4.8m	230	2.00-2.40	0,16	38,14	61.7
	Kab. Kaur Seluma						

No.	Kec. Seginim	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa. Pasar Baru	1.6m	44	1.40-1.80	49.76	48.95	1,96
	Kec. Seginim						

No.	Kec. Lubuk Sandi	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Tumbu'an	3m	80	2.00-2.40	0,23	34.98	64,79
	Lubuk Sandi						

No.	Kec. Air Napal	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa. Tepi Laut	6.4m	124	2.00-2.40	0,6	28,94	70,46
	Air Napal						