

DATA HASIL PENYELIDIKAN TANAH KAB. LAMPUNG SELATAN PROPINSI LAMPUNG

No.	Kec. Tanjung Sari	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Tanjung Sari	10,7	403	2,50 - 3,00	0	13,74	86,26
2	Desa Kerto Sari	5,80	58	2,00 - 2,40	0	19,09	80,91

No.	Kec. Natar	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Pemanggilan Natar	8,9	377	2,50 - 3,00	0	6,12	93,88
2	Desa Hajimena	8	285	2,50 - 3,00	0	6,17	93,83
3	Desa Merak Batin	4	227	2,00 - 2,50	1.12	39.59	59.29
4	Branti	4.6	214	BH	6.33	38.07	55.61

No.	Kec. Tanjung Bintang	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Kaliasin	8,1	337	2,50 - 3,00	0	14,96	85,04

No.	Kec. Padang Cemin	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Gebang	7,7m	248	2,10 - 2,40	44,02	51,04	4,95
2	Desa Suka Jaya	4m	136	2,00-2,40	15,4	57,07	28

No.	Kec. Tanjung Bintang	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Pasar Jati Baru	6,2m	171	2,10 - 2,40	2,69	61,8	35,51
2	Desa Serdang	2,1m	90	3,00 - 3,40	18,14	42,81	39,05

No.	Kec. Sukaharjo	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Banyumas	9,8m	214	2,10 - 2,40	13,26	14,6	72,14

No.	Kec. Jati Agung	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Karang Anyar	5,7m	194	2,00 - 2,40	1,85	7,91	90,25

No.	Kec. Penengahan	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Pasuruan	2,5m	114	1,60 - 2,00	3,69	12,83	83,48
2	Bakauheni 2	1,5m	49	1,00 - 1,40	28,54	30,58	40,88

No.	Kec. Palas	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Bangunan	1,5m	95	1,10 - 1,50	2,89	3,54	93,57
2	Gedung Tataan	0,8m	40	1,00 - 1,40	33,4	51,48	15,118
3	Padang Ratu	3,2m	62	1,10 - 1,50	0,05	15,7	84,25

No.	Kec. Kalianda	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Kel. Way Urang	5,10m	254	1,50 - 2,00	1.68	40.16	58.16