

**DATA HASIL PENELITIAN TANAH KAB.BANYU ASIN PROFINSI SUM-SEL**

No.	<b>Kec. Rambutan</b>	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Sungai Kedukan	14.6 m	224	2.50-3.00	0	3.76	96.24
2	Desa Sungai kedukan 2	17.20 m	237	2.50-3.00		0.73	99.27

No.	<b>Kec. Talang Kelapa</b>	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Suka Jadi	11.5 m	440	2.50-3.00	0	11.88	88.12
2	Desa Talang Kramat	12.20 m	457	2.50-3.00	0	1.7	98.3
3	Desa Suka Moro	7.70 m	289	2.50-3.00	0	0.66	99.34
4	Desa Tanah mas	10.60 m	253	2.50-3.00	0	0.98	99.02

No.	<b>Kec. Muara Padang</b>	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Tirtoraharjo	12.30 m	428	2.50-3.00	0	18.74	81.26

No.	Kec. Banyuasin 1	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Merah Mata	13.00 m	588	2.50-3.00	0	3.21	96.79
2	Desa Merah Mata 2	13.20 m	488	2.50-3.00	0	3.21	96.79

No.	Kec. Banyuaasin 11	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Talang Kramat	12.20 m	457	2.50-3.00	0	1.7	98.3

No.	Kec. Tanjung lago	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Suka Tani	14.40 m	453	2.50-3.00	0	0.93	99.07

No.	Kec. Air Shaleh	HASIL UJI LAPANGAN/SONDIR		Kedalaman Undisturbed Sample(m)	HASIL UJI LABORATORIUM		
		Kedalaman Tanah Keras(m) Pk > 150-200 Kg/Cm2	Jum.H.Lekat JHL (Kg/Cm2)		Sieve Analisis (%)		
					Kerikil	Pasir	Lempung
1	Desa Sri Katon	14.40 m	461	2.50-3.00	0	8.06	91.94

